



NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000194	DATE	09/14/2017
OWNER NAME	USDA-FOREST SERVICE	SYSTEM ID	1900020
SYSTEM NAME	USFS-MILL CREEK SUMMIT T-5	CLASS	TNC
SITE ADDRESS	27502 ANGELES FOREST HWY, ANGELES NATIONAL FOREST, CA 93550-9763		
MAILING ADDRESS	34534 116TH EAST PO BOX 1187, ARCADIA, CA 91006-2725		

California Health and Safety Code, Sections: 116275, 116650, 116555

California Code of Regulation, Title 22, Sections: 64422, 64423, 64424, 64426, 64426.1, 64463.1

Public water systems must comply with the Primary Standards for bacteriological quality.

To determine compliance with the Primary Standards for bacteriological quality, a public water system shall collect routine water sample(s) in accordance with the Bacteriological Sample Site Plan (BSSP) on file with the Los Angeles County Department of Public Health, Environmental Health Division (EH). The water sample(s) shall be analyzed by an approved laboratory for the presence of total coliform bacteria.

A public water system is in violation of the total coliform acute Maximum Contaminant Level (MCL) when any routine or repeat water sample(s) is positive for E-coli or fecal coliform bacteria.

Public water systems that violate the total coliform acute MCL shall issue a Tier 1 Public Notice.

The Tier 1 Public Notice shall be hand delivered to persons served by the water system and/or the notice shall be posted in conspicuous locations throughout the water system service area within 24 hours. The Tier 1 Public Notice shall be in effect until EH issues an official cancellation of the notice.



COUNTY OF LOS ANGELES ♦ DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH
Environmental Protection Branch
Drinking Water Program
5050 Commerce Drive, Baldwin Park, CA 91706
Phone: (626) 430-5420



NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000194	DATE	09/14/2017
OWNER NAME	USDA-FOREST SERVICE	SYSTEM ID	1900020
SYSTEM NAME	USFS-MILL CREEK SUMMIT T-5	CLASS	TNC
SITE ADDRESS	27502 ANGELES FOREST HWY, ANGELES NATIONAL FOREST, CA 93550-9763		
MAILING ADDRESS	34534 116TH EAST PO BOX 1187, ARCADIA, CA 91006-2725		

VIOLATION DESCRIPTION:

The water sample collected on September 11, 2017 was positive for total coliform; the water samples collected on September 13, 2017 were positive for total coliform and E. coli.

CORRECTIVE ACTION:

You are hereby directed by EH to comply with the Primary Standards for bacteriological quality, at once.

The Tier 1 Public Notice shall be hand delivered to persons served by the water system and/or the notice shall be posted in conspicuous locations throughout the water system service area within 24 hours. The Tier 1 Public Notice shall be in effect until EH issues an official cancellation of the notice.

Certification of the delivery and/or posting of the Tier Public Notice must be completed and returned to EH at swsadmin@ph.lacounty.gov.

You may contact the Drinking Water Program at 626-430-5420 for any questions regarding this enforcement action.

Lusi Mkhitarian
Chief Environmental Health Specialist

Enclosures: Tier 1 Public Notice
Certification for Tier Public Notice